


# WWTP RENOVATION AND EXPANSION




Engineering Study – Preliminary Results  
November 15, 2018

# SAN MIGUEL CSD WASTEWATER SYSTEM

- ▶ 737 Connections
- ▶ Population Served: 2700



# EXISTING WWTP CONFIGURATION




# EXISTING PERMIT REQUIREMENTS

- |                                     |                            |                |
|-------------------------------------|----------------------------|----------------|
| ▶ Permitted Treatment Capacity, MGD | 0.2 (max. month)           |                |
| ▶ Effluent Limitations:             | <u>Avg. last 6 samples</u> | <u>Maximum</u> |
| ▶ TDS, mg/L                         | 825                        | 900            |
| ▶ Chloride, mg/L                    | 180                        | 200            |
| ▶ Sulfate, mg/L                     | 175                        | 200            |
| ▶ Sodium, mg/L                      | 150                        | 170            |
- ▶ The treatment ponds must maintain a minimum 2.0 feet freeboard at all times and must maintain dissolved oxygen of 1.0 mg/L minimum at all times.
  - ▶ Effluent pH shall range between 6.5 and 8.4 at all times.
  - ▶ Discharge shall not cause nitrate concentrations in downgradient GW to exceed 5 mg/L (as N)
  - ▶ Discharge shall not cause “significant” increase in TDS.
  - ▶ Under the current WDRs, the SMCS D is not required to sample influent or effluent organic waste strength parameters (total suspended solids (TSS) or biochemical oxygen demand (BOD<sub>5</sub>)). However, the District must submit quarterly monitoring reports, and submit an annual report summarizing the past year’s effluent and disposal area monitoring.

# WWTP HISTORIC FLOW SUMMARY

## ▶ AVG. Daily Flows





# FUTURE EFFLUENT QUALITY NON-TITLE 22

- ▶ “30/30/10”
- ▶ Reduce Salt Loading to GW Basin

Constituent	Units	Current Limit		Potential Future Limit
		Average of the last 6 samples	Maximum	
TDS	mg/L	825	900	Same as Current
Chloride	mg/L	180	200	Same as Current
Sulfate	mg/L	175	200	Same as Current
Sodium	mg/L	150	170	Same as Current
Dissolved Oxygen	mg/L	No less than 1.0 mg/L in all lagoons at any time		Same as Current
pH	pH units	6.5-8.4		Same as Current
5-Day Biological Oxygen Demand (BOD <sub>5</sub> )	mg/L	None		30
Total Suspended Solids (TSS)	mg/L	None		30
Total Nitrogen, as N (TN)	mg/L	None		10



# FUTURE PROJECTED FLOWS

Flow Condition	Peaking Factor	Existing Flow (mgd)	Projected Flow (mgd)			
			2023	2028	2035	2050
Average Daily Flow (ADF)	--	0.170	0.195	0.210	0.255	0.470
Maximum Day Dry Weather Flow (MDDWF)	1.25	0.213	0.244	0.263	0.319	0.588
Maximum Day Wet Weather Flow (MDWWF)	1.5	0.255	0.293	0.315	0.383	0.705
Peak Hour Wet Weather Flow (PHWWF)	3.5	0.595	0.683	0.735	0.893	1.645
Estimated Population Served		2700	3000	3350	3700	6300
Estimated Number of sewer connection		765	850	900	1050	1800
Annual Discharge (AC-FT)		190	220	240	290	530
Annual Discharge (AC-FT) w/ Gallo Wastewater		230	260	280	330	570
<sup>1</sup> Projected ADF, population increase, and sewer connections are based on SMCSO Water & Wastewater Masterplan Update, land Use in San Miguel (Monsoon Consultants, November 2017)						
<sup>2</sup> It should be noted that the peaking factor for computing the MDWWF for future conditions was reduced from 4.0 to 3.5.						
<sup>3</sup> They system flow, up to 2035, is based upon a a single person 65 gpcd. From 2050, the average per person is increased to 75 because it's estimated that new developed area will use more water compared to the current socio economic community that is present today.						
<sup>4</sup> The projected treatment system life expectancy is roughly 25-30 years.						

# BASIC WWTP OPERATIONS/PROCESSES

- Wastewater treatment is a process used to convert wastewater into an effluent that can be returned to the water cycle with minimum impact on the environment, or directly reused. The basic processes include the following:
    - Headworks
    - Influent Lift Station
    - Primary Treatment
    - Secondary Treatment
    - Bio-Solids Handling
    - Tertiary Treatment
    - Disinfection
    - Recycled Water Supply / Transmission
- 

# SMCSD WWTP EXPANSION/UPGRADE ALTERNATIVES EVALUATION CRITERIA

- ▶ Evaluate Processes Based On:
    - Utilization of Existing Facilities & Available Land
    - Identification of Scalable Processes To Permit Future Growth
    - Cost (Capital, O & M) vs Benefit
    - Compatibility with Existing Operations Staff Expertise
    - Mitigation of Odor Compounds
    - System Reliability
    - Quality of Effluent
- 

# WWTP EXPANSION / UPGRADE ALTERNATIVES

- ▶ COMMON IMPROVEMENTS
  - ▶ TREATMENT ALTERNATIVES
    - Primary Processes
    - Secondary Treatment Processes
    - Tertiary Treatment Processes
    - Secondary–Tertiary Treatment Processes
    - Disinfection Treatment Processes
    - Bio–Solids Treatment and Disposal Processes
    - Title 22 Recycled Water Supply System
- 


# COMMON IMPROVEMENTS



# COMMON IMPROVEMENTS


- ▶ Septage Receiving Station
  - ▶ Headworks
    - Screening
    - Grit Removal
  - ▶ Influent Pumping Station
  - ▶ Office and Laboratory Facilities
  - ▶ Additional Maintenance & Equipment Storage/Shop Facilities
  - ▶ Environmentally Controlled Electrical & Controls Facilities
  - ▶ Upgrade & Modernization of the Electrical, Controls & SCADA Systems
  - ▶ Upgrade Power Generation Facilities
- 

# PRIMARY TREATMENT PROCESSES



# PRIMARY PROCESSES

- ▶ Flow Equalization
  - Aerated
  - Non-Aerated



# SECONDARY TREATMENT PROCESSES



# SECONDARY TREATMENT ALTERNATIVES

- ▶ Activated Sludge
  - ▶ Activated Sludge w/ Membrane Bio-Reactor
  - ▶ Trickling Filter
  - ▶ Trickling Filter w/ Membrane Bio-Reactor
  - ▶ Membrane Bio-Reactor
  - ▶ Rotating Biological Contactors
  - ▶ Rotating Biological Contactors w/ Membrane Bio-Reactor
  - ▶ Moving Bed Bio-Reactor w/ Membrane Bio-Reactor
  - ▶ Integrated Fixed Film Activated Sludge
  - ▶ Modified Aerated Ponds w/ Sequence Batch Reactor
  - ▶ Modified Aerated Ponds w/ Anoxic/Oxic Tanks
  - ▶ Renovated Aerated Ponds w/ Anoxic/Oxic Tanks
  - ▶ Modified Aerated Pond w/ Membrane Bio-Reactor
  - ▶ Modified Aerated Pond w/ Moving Bed Bio-Reactor
  - ▶ Sequence Batch Reactor
  - ▶ Modified Aerated Pond w/ Oxidation Ditch
  - ▶ Oxidation Ditch
  - ▶ Activated Sludge w/ Packed Bed Reactor and Membrane Bio-Reactor
  - ▶ Renovated / Retrofitted Ponds
- 

# SECONDARY PROCESSES EVALUATION MATRIX

Secondary Treatment - Suspended Growth Biological Treatment Systems											
Criteria	Weight(%)	Activated Sludge (AS)		Sequencing Batch Reactor (SBR)		Oxidation Ditch		Retro-Fitted Aerated Ponds		Membrane BioReactor (MBR)	
		Raw	Weighted	Raw	Weighted	Raw	Weighted	Raw	Weighted	Raw	Weighted
Capital Cost	20	2.5	0.5	4	0.8	3	0.6	5	1	3	0.6
Operating Cost	20	4	0.8	4	0.8	3	0.6	3	0.6	3	0.6
Odor Mitigation	5	4	0.2	4	0.2	4	0.2	3	0.15	4	0.2
Staff Requirement	5	3	0.15	3	0.15	4	0.2	3	0.15	3	0.15
Reliability	10	4	0.4	4	0.4	4	0.4	4	0.4	5	0.5
Construction Feasibility	10	3	0.3	4	0.4	4	0.4	5	0.5	4	0.4
Ease of O&M	5	3	0.15	3	0.15	4	0.2	3	0.15	3	0.15
Adaptability/ Scalability	5	2	0.1	5	0.25	2	0.1	4	0.2	4	0.2
Effluent Quality	10	4	0.4	4	0.4	4	0.4	4	0.4	5	0.5
Footprint	10	3	0.3	5	0.5	2	0.2	5	0.5	4	0.4
<b>Total</b>	<b>100</b>		<b>3.3</b>		<b>4.05</b>		<b>3.3</b>		<b>4.05</b>		<b>3.7</b>

\*Membrane BioReactor is a combined secondary/tertiary treatment system

# SECONDARY ALTERNATIVE EVALUATION MATRIX CONT.




Secondary Treatment - Fixed Film Biological Treatment System									
Criteria	Weighted(%)	Trickling Filters (TF)		Rotating Biological Contactors (RBC)		Moving Bed Biofilm Reactors (MBBR)		Integrated Fixed-Film Activated Sludge (IFAS)	
		Raw	Weighted	Raw	Weighted	Raw	Weighted	Raw	Weighted
Capital Cost	20	2.5	0.5	2.5	0.5	2	0.4	2	0.4
Operating Cost	20	3	0.6	3	0.6	2	0.4	2	0.4
Odor Mitigation	5	2.5	0.125	4	0.2	4	0.2	4	0.2
Staff Requirement	5	4	0.2	3	0.15	2.5	0.125	2.5	0.125
Reliability	10	3	0.3	3	0.3	4	0.4	4	0.4
Construction Feasibility	10	4	0.4	3	0.3	4	0.4	3	0.3
Ease of O&M	5	2.5	0.125	3	0.15	3	0.15	2.5	0.125
Adaptability/ Scalability	5	3	0.15	2	0.1	4	0.2	3	0.15
Effluent Quality	10	3	0.3	3	0.3	4.5	0.45	5	0.5
Footprint	10	4	0.4	3	0.3	4	0.4	3	0.3
<b>Total</b>	<b>100</b>		<b>3.1</b>		<b>2.9</b>		<b>3.125</b>		<b>2.9</b>

# TERTIARY TREATMENT PROCESSES



# TERTIARY TREATMENT – FILTRATION PROCESSES


- ▶ Disk Filters
- ▶ Granular Media Filters
- ▶ Membrane Filters (microfiltration and ultrafiltration)



# TERTIARY TREATMENT – FILTRATION EVALUATION MATRIX



Tertiary Treatment - Filtration Treatment Systems							
Criteria	Weighted(%)	Disc Filters		Media Filters		Membrane Filters	
		Raw	Weighted	Raw	Weighted	Raw	Weighted
Capital Cost	20	4	0.8	3	0.6	2	0.4
Operating Cost	20	3	0.6	3	0.6	2	0.4
Odor Mitigation	5	5	0.25	5	0.25	5	0.25
Staff Requirement	5	4	0.2	4	0.2	3	0.15
Reliability	10	3	0.3	3	0.3	4	0.4
Construction Feasibility	10	4	0.4	3	0.3	4	0.4
Ease of O&M	5	4	0.2	4	0.2	3	0.15
Adaptability/ Scalability	5	4	0.2	3	0.15	3	0.15
Effluent Quality	10	4	0.4	4	0.4	5	0.5
Footprint	10	4	0.4	3	0.3	2.5	0.25
<b>Total</b>	<b>100</b>		<b>3.75</b>		<b>3.3</b>		<b>3.05</b>

# HYBRID SECONDARY – TERTIARY TREATMENT PROCESSES




# COMBINED SECONDARY/TERTIARY TREATMENT

## ▶ Membrane Bio-Reactor




# DISINFECTION PROCESSES



# DISINFECTION PROCESS

- ▶ Chlorination/Dechlorination Basin
- ▶ UV Light



# DISINFECTION PROCESSES EVALUATION MATRIX



Tertiary Treatment - Disinfection Treatment Systems					
Criteria	Weighted(%)	UV Disinfection		Chlorine Disinfection	
		Raw	Weighted	Raw	Weighted
Capital Cost	20	3	0.6	3	0.6
Operating Cost	20	2	0.4	3	0.6
Odor Mitigation	5	5	0.25	4	0.2
Staff Requirement	5	3	0.15	3	0.15
Reliability	10	3	0.3	4	0.4
Construction Feasibility	10	4	0.4	3	0.3
Ease of O&M	5	4	0.2	3	0.15
Adaptability/ Scalability	5	4	0.2	3	0.15
Effluent Quality	10	4	0.4	3	0.3
Footprint	10	4	0.4	3	0.3
<b>Total</b>	<b>100</b>		<b>3.3</b>		<b>3.15</b>

# SLUDGE MANAGEMENT PROCESSES



# BIOSOLIDS MANAGEMENT PROCESSES


- ▶ Sludge Drying Bed
- ▶ Dewatering Container Filters (Sludge Box)
- ▶ Screw Press



# BIOSOLIDS MANAGEMENT PROCESSES EVALUATION MATRIX

Tertiary Treatment - Bio-Solids Handling Systems							
Criteria	Weighted(%)	Sludge Drying Bed		Dewatering Container Filters (Sludge Box)		Screw Press	
		Raw	Weighted	Raw	Weighted	Raw	Weighted
Capital Cost	20	5	1	4	0.8	3	0.6
Operating Cost	20	3	0.6	4	0.8	4	0.8
Odor Mitigation	5	2	0.1	4	0.2	3	0.15
Staff Requirement	5	2	0.1	4	0.2	4	0.2
Reliability	10	3	0.3	4	0.4	4	0.4
Construction Feasibility	10	5	0.5	5	0.5	5	0.5
Ease of O&M	5	3	0.15	4	0.2	4	0.2
Adaptability/ Scalability	5	2	0.1	4	0.2	4	0.2
Effluent Quality	10	4	0.4	4	0.4	4	0.4
Footprint	10	3	0.3	4	0.4	5	0.5
<b>Total</b>	<b>100</b>		<b>3.55</b>		<b>4.1</b>		<b>3.95</b>

# CASE STUDIES



# NIPOMO WASTEWATER TREATMENT FACILITY

- ▶ Permitted Capacity of 0.9 MGD, Operating at 0.6 MGD
  - ▶ The current plant included 4 aerated ponds, 2 sludge drying beds, and 8 percolation basins.
  - ▶ Projected Effluent and Flow limits Would Be Reached Soon
  - ▶ Four Treatment Processes Were Evaluated for the WWTF Upgrade:
    - A. ADDITIONAL AERATED PONDS
    - B. BIOLAC WAVE OXIDATION SYSTEM
    - C. OXIDATION DITCH
    - D. CONVENTIONAL ACTIVATED SLUDGE
  - ▶ Selected Treatment Option was **RETROFITTED POND SYSTEM**
- 

# KING CITY WASTEWATER TREATMENT FACILITY

- ▶ Permitted Capacity of 1.2 MGD, Operating at 0.85 MGD
- ▶ The current plant included head works, seven aerated ponds, an effluent disposal pump station and force man, and six spray irrigation fields for disposal of treated effluent. Projected effluent and flow limits would be reached soon
- ▶ Initially, multiple options were considered:
  - 1.) Activated Sludge
  - 2.) Trickling Filter (1-stage)
  - 3.) Nitrifying Trickling Filter Etinger (MLE) Process
  - 4.) Denitrification Filters
  - 5.) Additional Ponds
  - 6.) Conventional Activated Sludge (CAS) W/ Modified Ludzach-Etinger (MLE) Process
  - 7.) Oxidation Ditch
  - 8.) MBR
- ▶ Based on BOD removal, Ammonia removal, Total Nitrogen removal, reliability and recommendations made by Carollo, the 3 investigated further included:
  - A. **Conventional Activated Sludge (CAS) W/ Modified Ludzach-Etinger (MLE) process**
  - B. **Oxidation Ditch**
  - C. **MBR**
- ▶ These three systems were evaluated based on a matrix that included performance, footprint, constructability, operation and maintenance requirements, economic factors, and safety. The highest score received was by **Oxidation Ditch**, which was selected as the alternative.


# MORRO BAY WASTEWATER TREATMENT FACILITY

- ▶ Design ADF Of 1.5 MGD, Operating At 1.25 MGD
  - ▶ The current plant included bar screens, aerated Grit Basin, 2 primary clarifiers, 2 trickling filters, solids contact chamber, secondary clarifier, chlorine contact basin, and effluent discharged to the ocean. The systems sludge was sent to a digester.
  - ▶ Multiple treatment Processes were looked at but two were evaluated for the WWTF upgrade:
    - A. SBR
    - B. MBR
    - C. OXIDATION DITCH
- Selected treatment option was **MBR System**
- 

# WWTP EXPANSION / UPGRADE PREFERRED ALTERNATIVE CONFIGURATIONS




**Retrofitted Existing Pond System  
Sequencing Batch Reactor (SBR)  
Membrane Bio-Reactor (MBR)**





# RETROFITTED EXISTING POND SYSTEM (HYBRID SBR)

## ► Summary of Configuration

- Headworks
- Influent Lift Station
- Aerated Flow Equalization
- Hybrid SBR Pond System
- Tertiary Filtration
- UV Disinfection
- Biosolids Handling
- Recycled Water System



# RETROFITTED POND SYSTEM (HYBRID SBR)




## EXISTING HYBRID SBR POND SYSTEMS

<b>NAME OF FACILITY</b>	<b>LOCATION (CITY, STATE)</b>	<b>ADF</b>
Lexington WWTP	Lexington, Tennessee	1.1 MGD
City of Rupert Wastewater Treatment Plant	Rupert, Idaho	2.6-3.0 MGD
Mountain Green Sewage District Plant	Mt. Green, Utah	0.2-0.6 MGD
Grantsville WWTP	Grantsville, Utah	1.5 MGD
Brakebush Brothers Inc., Poultry	Westfield, Wisconsin	0.1 MGD
F&A Dairy Products, Inc.	Dresser, Wisconsin	0.1 MGD
Miner WWTP	Miner, Missouri	0.3 MGD



# SEQUENCING BATCH REACTOR

## ► Summary of Configuration

- Headworks
- Influent Lift Stations
- Aerated Flow Equalization
- SBR Unit
- Tertiary Filtration
- UV Disinfection
- Biosolids Handling
- Recycled Water System



# SEQUENCING BATCH REACTOR SYSTEM




OMNIPAC® Field - Erected SBR system layout

# EXISTING SEQUENCING BATCH REACTOR SYSTEMS

<b>NAME OF FACILITY</b>	<b>LOCATION (CITY, STATE)</b>	<b>ADF</b>
Siletz WWTP	Siletz, Oregon	90-200,000
Mingus WWTP	Cottonwood, Arizona	1,000,000
Sometron WWTP	Somerton, Arizona	800,000
Cave Creek WWTP	Cave Creek, Arizona	300,000
Pala Casino Spa & Resort WWTP	Pala , California	600,000
Coquille Sewage TP	Coquille, Oregon	6.12 MGD
Creswell WTF	Creswell, Oregon	800,000
Sun Lakes WWTP	Sun Lakes, Arizona	2.4 MGD
Sundance Water Reclamation Facility	Buckeye, Arizona	1.2 MGD
Mountain House Water Reclamation Facility	(near Tracy), California	3 MGD
Cypress Ridge WWTP	Arroyo Grande, California	0.14 MGD
Calera Creek WRP	Pacifica, California	3.30 MGD
Santa Rosa Rancheria	Lemoore, California	0.55 MGD
Table Mountain Rancheria	Friant, California	0.5 MGD

# MEMBRANE BIO-REACTOR

- ▶ Summary of Configuration
  - Headworks
  - Influent Lift Station
  - Non-Aerated Flow Equalization
  - Micro Screening
  - MBR Unit
  - UV Disinfection
  - Biosolids Handling
  - Recycled Water System




# EXISTING MEMBRANE BIO-REACTOR SYSTEMS

<b>NAME OF FACILITY</b>	<b>LOCATION (CITY,STATE)</b>	<b>ADF</b>
Quechan Paradise Casino	Winterhaven, Ca	600,000 GPD
Double Tree Paper Mill Facility	Gila Bend, Az	300,000 GPD
Corona WWTP	Carona, Ca	3.8-8.5 MGD
Tri-City water Pollution Control Plant (WPCP)	Oregon City, Clackamas County, Oregon	4 MGD
San Luis Obispo WRRF MBR upgrade	San Luis Obispo, CA	3 MGD
Ironhouse Sanitary District WWTP	Countra Costa County, CA	8.6 MGD
Redlands WWTP	San Bernardino County, CA	6.6 MGD
Santa Paula WWTP	Ventura County, CA	4.2 MGD
American Canyon WWTP	Napa County, CA	3.75 MGD
Red Hawk Casino WWTP	CA	0.3 MGD
*Morro Bay WWTP(in progress, deciding on MBR Manufacturer)	Morro Bay, CA	1.1 MGD


# SHORT-LIST EVALUATION MATRIX

Criteria	Weight(%)	Recommended Treatment Systems					
		Retro-Fitted Aerated Ponds		Sequencing Batch Reactor (SBR)		Membrane BioReactor	
		Raw	Weighted	Raw	Weighted	Raw	Weighted
Capital Cost	20	5	1	4	0.8	3	0.6
Operating Cost	20	3	0.6	4	0.8	3	0.6
Odor Mitigation	5	3	0.15	4	0.2	4	0.2
Staff Requirement	5	3	0.15	3	0.15	3	0.15
Reliability	10	4	0.4	4	0.4	5	0.5
Construction Feasibility	10	5	0.5	4	0.4	4	0.4
Ease of O&M	5	3	0.15	3	0.15	3	0.15
Adaptability/ Scalability	5	4	0.2	5	0.25	4	0.2
Effluent Quality	10	4	0.4	4	0.4	5	0.5
Footprint	10	5	0.5	5	0.5	4	0.4
<b>Total</b>	<b>100</b>		<b>4.05</b>		<b>4.05</b>		<b>3.7</b>


# SALT MANAGEMENT STRATEGY



# SODIUM TRENDS IN EFFLUENT



# CHLORIDE TRENDS IN EFFLUENT




# SALT REDUCTION THROUGH BLENDING


- ▶ RECYCLED WATER THAT MEETS TITLE 22 DISINFECTED SECONDARY STANDARDS CAN BE USED FOR VINEYARD DRIP IRRIGATION SYSTEMS
  - ▶ MIXING RECYCLED WATER WITH WELL WATER PRODUCED BY VINEYARDS WILL PRODUCE A IRRIGATION SUPPLY THAT IS SUITABLE FOR VINE HEALTH
  - ▶ ELIMINATE THE PERCOLATION OF EFFLUENT WITH HIGH SALT CONCENTRATIONS INTO THE GROUNDWATER AQUIFER
  - ▶ DISTRIBUTE THE PRODUCED MASS OF SALT OVER A SIGNIFICANT AREA (MINIMAL ADVERSE IMPACT TO THE GROUNDWATER BASIN)
  - ▶ REDUCED PUMPING FROM NEARBY VINEYARD IRRIGATION WELLS
  - ▶ POTENTIAL SIGNIFICANT LONG-TERM INCOME SOURCE FOR DISTRICT
- 

# RECYCLED WATER SUPPLY SYSTEM

## Proposed SMCS D Title 22 Recycled Water Transmission Pipeline Alignment



# PRELIMINARY WWTP EXPANSION / UPGRADE CAPITAL COST ESTIMATES



# COMPARISON OF ESTIMATED CAPITAL COSTS

- ▶ RETROFITTED EXISTING POND SYSTEM – \$4,360,000
- ▶ SEQUENCING BATCH REACTOR SYSTEM – \$4,950,000
- ▶ MEMBRANE BIO-REACTOR SYSTEM – \$5,950,000

ESTIMATED WWTP EXPANSION / UPGRADE ESTIMATE PER 2017 MASTER PLAN UPDATE – \$4,559,300

- ▶ Note: Not included in each of these configurations cost estimates is the estimated cost of for a Recycled Water Storage / Pumping / Transmission System to Deliver Treated Effluent to Large Vineyards for Irrigation Purposes is \$2,380,000.
- 

# WHATS NEXT?

- ▶ Complete Engineering Report and Delivered to Board
  - ▶ Initiate CEQA Process
  - ▶ Meet with Water Board to Solicit Input and Direction
  - ▶ Initiate District Operations Staff Diligence Investigations
  - ▶ Selection of Final WWTP Expansion / Upgrade Configuration
  - ▶ Submittal of Grant Funding Applications
  - ▶ WWTP Expansion / Upgrade Design Development
  - ▶ Initiate Permitting Process
  - ▶ WWTP Expansion / Upgrade Construction Documentation
  - ▶ Initiate Project Financing Activities
  - ▶ Complete CEQA Process and Permitting
  - ▶ Initiate Project Solicitation for Bids
  - ▶ Contract Award and Begin Construction
- 